



Smithfield City
96 S. Main Street, Smithfield, UT 84335
(435) 563-6226 www.smithfieldcity.com

FIRE HYDRANT USE PERMIT

PERMIT NO. _____

PERMIT HOLDER _____

VEHICLE I.D. _____

ADDRESS _____

VEHICLE LICENSE # _____

VEHICLE MAKE: _____

USE OF VEHICLE _____

PERMIT FEE: \$1200.00

DATE OF ISSUE: _____

BACKFLOW PREVENTION

Type of backflow prevention assembly _____

Backflow prevention assembly meets minimum standards Yes No

Water Superintendent _____

AUTHORIZED HYDRANT LOCATION: _____ **See Attached List**

AUTHORIZED TIME OF OPERATION: _____ **8:00 a.m. to 5:00 p.m.**

**THIS PERMIT IS NONTRANSFERABLE AND IS VALID FOR THE ABOVE SPECIFIED EQUIPMENT WHICH HAS BEEN INSPECTED AND FOUND TO MEET THE MINIMUM REQUIREMENTS FOR BACKFLOW PREVENTION.*

Effective Period

_____ *To* _____

* Use confined to city limits only.

FIRE HYDRANT USE PROCEDURES

- Hydrants are only to be operated using auxiliary valves supplied the permittee.
- Once auxiliary valves are connected to the fire hydrant, the hydrant operating nut shall be fully opened. The filling of water tanks shall only be done through the use of the auxiliary valve.
- Only auxiliary valves and fill hoses which are free from leaks will be allowed.
- Following the filling of the water tank the auxiliary valve shall be slowly closed to prevent water hammer, the hydrant operating nut shall then be closed, and the fill hose and auxiliary valve removed.
- Check to ensure the hydrant is fully closed. Water should be receding away from the hydrant nozzle and draining down the inside of the hydrant barrel.
- Only fire hydrants listed on the permit shall be used by the permittee.
- Use of fire hydrants not specified on the permit or use of hydrants at times and dates not permitted shall be grounds for revoking of the permit.
- The permittee shall be responsible for any damage to the fire hydrants as a result of their failure to follow these procedures or carelessness.